



EAN code
CU3-09M/DALI: 8595188184656

Technical parameters CU3-09M/DALI

Indication LED STATUS	
Green - RUN:	The main program runs
Red - ERR:	The main program stalled
Communication	
System BUS	
Maximum number of units:	max. 32 Units
Status indication (LED BUS):	Green: Bus Operating Status red: error indication on the bus
Bus power supply:	external DALI power supply must be connected
Ethernet	
Connector:	RJ45
Communication speed:	100 Mbps
Ethernet status indication (LED ETH):	green - Ethernet communication yellow - speedEthernet 100 Mbps
Default IP address:	192.168.1.1
RESET button	
Restart:	short press
Reset (return to factory settings):	press the button to bring power on, button release 10 s after power is supplied
Power	
Supply voltage/tolerance:	27 V DC, -20/+10 %
Rated current:	50 mA (at 27 V DC)
Operating conditions	
Working temperature:	-20 to +55 °C
Storage temperature:	-25 to +70 °C
Air humidity:	max. 80%
Degree of protection:	IP20 device, IP40 with cover in the control cabinet
Surge Category:	II.
Degree of pollution:	2
Working position:	any
Installation:	to the control cabinet for DIN rail EN 60715
Design:	1-MODULE
Terminal plate:	max. 2.5 mm ²
Dimensions and weight	
Dimensions:	94 x 17.6 x 64 mm
Weight:	72 g

- CU3-09M is one of the basic system control units of iNELS BUS installations.
- The unit can work independently, as an autonomous project, or it can be controlled by the IP-MASTER as part of a larger project.
- The unit is equipped with one BUS to switch it is possible to connect up to 32 elements from the iNELS BUS portfolio.
- The current load of one line is max. 1 A. BPS3-01M with 3 A can be used in case of connected device with more than 1 A.
- The CU3-09M/DALI system unit is equipped with one DALI bus.
- The DALI system bus allow control of up to 64 independent DALI ballast addresses for luminaires.
- Addressing of DALI can be done via the iDM software.
- The RJ45 100 Mbps Ethernet connector is used for direct communication with the cloud for mobile app control or for communication with the superior unit within the iNELS IP topology.
- Configuration takes place in the iNELS3 Designer & Manager software (iDM3).
- Through iDM3 it is possible to update the firmware of central units and bus connected peripheral units.
- The unit is powered by 27 V DC from inels power supply. BUS1 can power the central unit.
- System units CU3-09M in 1-MODULE design are designed for mounting into a switchboard on DIN rail EN60715.

Connection

